



Burlington WA  
Corporate Office

1620 S Walnut St - 98233  
800.755.9295 • 360.757.1400

Bellingham WA  
Microbiology

805 W Orchard Dr Ste 4 - 98225  
360.671.0688

Portland OR  
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W- 97070  
503.682.7802

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Beverly Beach Improvement Club**  
PO BOX 12  
Freeland, WA 98249

Reference Number: 11-14109  
Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
System ID Number: 061475  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: X-3 Hose Bib  
County: Island  
Sampled By: Joe Waldrup  
Sampler Phone:

Repeat Sample Number:  
Lab Number: 164-31134  
Field ID: 1  
Date Collected: 9/6/11 09:10  
Date Received: 9/6/11  
Date Analyzed: 9/07/11 11:45  
Report Date: 9/7/11  
Comment: Cl2:0.21mg/L  
Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	<b>Satisfactory, Coliforms Absent</b>	per 100mL	rma	SM9223 B	M_110906	
3	E. COLI	<b>Absent</b>	per 100mL		SM9223 B	M_110906	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.