



Burlington WA
Corporate Office

1620 S Walnut St - 98233
800.755.9295 • 360.757.1400

Bellingham WA
Microbiology

805 W Orchard Dr Ste 4 - 98225
360.671.0688

Portland OR
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W- 97070
503.682.7802

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club
PO BOX 12
Freeland, WA 98249

Reference Number: 12-06849
Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID Number: 061475
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: X2 Hose Bib
County: Island
Sampled By: Joe Waldrup
Sampler Phone: 360-625-2457

Repeat Sample Number:
Lab Number: 164-15697
Field ID: 1
Date Collected: 5/1/12 08:00
Date Received: 5/1/12
Date Analyzed: 5/02/12 12:00
Report Date: 5/2/12
Comment: CI2: 0.30
Peer Review:

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	slm	SM9223 B	m_120501	
3	E. COLI	Absent	per 100mL		SM9223 B	m_120501	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.