



Burlington WA A      Bellingham WA B      Portland OR C  
 Corporate Office      Microbiology      Microbiology/Chemistry  
 1620 S Walnut St - 98233      805 W Orchard Dr Ste 4 - 98225      9150 SW Pioneer Ct Ste W- 97070  
 800.755.9295 • 360.757.1400      360.671.0688      503.682.7802



## DISINFECTION BY-PRODUCT COMPOUNDS REPORT

Client Name: Beverly Beach Improvement Club  
 PO BOX 12  
 Freeland, WA 98249

Reference Number: 13-15150  
 Project: DBP

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
 System ID Number: 06147  
 DOH Source Number: 92 - Distribution Sample  
 Multiple Sources:  
 Sample Type: A - After treatment  
 Sample Purpose: C - Compliance  
 Sample Location: X-2 Hose Bibb  
 County: Island  
 Sampled By: Joe Waldrup  
 Sampler Phone: 360-675-2457

Field ID: DBP  
 Lab Number: 046-34549  
 Date Collected: 8/15/13 10:20  
 Date Extracted: THM\_130819  
 Date Analyzed: 08/19/13  
 Report Date: 8/23/13  
 Analyst: HY  
 Released By:

### EPA Method 524.2 For State Drinking Water Compliance

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	COMMENT
<b>EPA Regulated - Under Trihalomethanes Program</b>							
27	CHLOROFORM	78.5	ug/L	0.5			
28	BROMODICHLOROMETHANE	22.9	ug/L	0.5			
29	CHLORODIBROMOMETHANE	4.9	ug/L	0.5			
30	BROMOFORM	ND	ug/L	0.5			
31	TOTAL TRIHALOMETHANE	106.3	ug/L		60	80	Field Dup: 106.3 ug/L

**NOTES:**  
 If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected); indicates that the parameter was not detected above the State Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.  
 Lab - Indicates where parameter was analyzed. See header address for lab code.  
**These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.**  
**If you have any questions concerning this report contact Lawrence Henderson at the above phone number.**  
 FORM: cODBP.rpt