



Burlington WA
Corporate Office

1620 S Walnut St - 98233
800.755.9295 • 360.757.1400

Bellingham WA
Microbiology

805 Orchard Dr Ste 4 - 98225
360.671.0688

Portland OR
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W- 97070
503.682.7802



INORGANIC COMPOUNDS (IOC) REPORT

Client Name: **Beverly Beach Improvement Club**
PO BOX 12
Freeland, WA 98249

Reference Number: 13-23003
Project: DBP

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID Number: 06147
DOH Source Number: 02
Multiple Sources:
Sample Type: B - Before treatment
Sample Purpose: C - Compliance
Sample Location: Beverly Beach Improvement Club
County: Island

Sample Number: CI, Ec
Lab Number: 046-52682
Collect Date: 12/5/13 09:00
Date Received: 12/5/13
Report Date: 12/11/13
Sampled By: Joe Waldrup
Sampler Phone:
Released by:

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Analyzed	COMMENT
16	Other ELECTRICAL CONDUCTIVITY	362	uS/cm	10		700	srf	SM2510 B	12/09/13	
21	EPA Regulated (Secondary) CHLORIDE	14	mg/L	0.1		250	bj	300.0	12/06/13	

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).
An * in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.

If you have any questions concerning this report contact us at the above phone number.