



Burlington WA A Corporate Office 1620 S Walnut St - 98233 800.755.9295 • 360.757.1400  
 Bellingham WA B Microbiology 805 W Orchard Dr Ste 4 - 98225 360.671.0688  
 Portland OR C Microbiology/Chemistry 9150 SW Pioneer Ct Ste W- 97070 503.682.7802



## DISINFECTION BY-PRODUCT COMPOUNDS REPORT

Client Name: Beverly Beach Improvement Club  
 PO BOX 12  
 Freeland, WA 98249

Reference Number: 14-09968  
 Project: DBP

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
 System ID Number: 06147  
 DOH Source Number: 92 - Distribution Sample  
 Multiple Sources:  
 Sample Type: A - After treatment  
 Sample Purpose: C - Compliance  
 Sample Location: X-1 Hose Bibb  
 County: Island  
 Sampled By: Joe Waldrup  
 Sampler Phone: 360-675-2457

Field ID: DBP  
 Lab Number: 046-23919  
 Date Collected: 6/3/14 08:00  
 Date Extracted: THM\_140605  
 Date Analyzed: 06/05/14  
 Report Date: 6/10/14  
 Analyst: EM  
 Released By:

### EPA Method 524.2 For State Drinking Water Compliance

DOH#	COMPOUNDS	RESULTS	UNITS	SRL	Trigger	MCL	COMMENT
<b>EPA Regulated - Under Trihalomethanes Program</b>							
27	CHLOROFORM	8.2	ug/L	0.5			
28	BROMODICHLOROMETHANE	1.9	ug/L	0.5			
29	CHLORODIBROMOMETHANE	ND	ug/L	0.5			
30	BROMOFORM	ND	ug/L	0.5			
31	TOTAL TRIHALOMETHANE	10.1	ug/L		60	80	

**NOTES:**  
 If a compound is detected > or = to the State Reporting Level, SRL, specified increased monitoring frequencies may occur per DOH.  
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.  
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.  
 ND (Not Detected): indicates that the parameter was not detected above the State Reporting Limit (SRL).  
 An \* in front of the parameter name indicates it is not NELAP accredited but it is accredited through WSDOH or USEPA Region 10.  
 Lab - Indicates where parameter was analyzed. See header address for lab code.  
 These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples.  
 If you have any questions concerning this report contact Lawrence Henderson at the above phone number.  
 FORM: cODBP.rpt