



Burlington WA
Corporate Office

1620 S Walnut St - 98233
800.755.9295 • 360.757.1400

Bellingham WA
Microbiology

805 W Orchard Dr Ste 4 - 98225
360.671.0688

Portland OR
Microbiology/Chemistry

9150 SW Pioneer Ct Ste W- 97070
503.682.7802

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: **Beverly Beach Improvement Club**
PO BOX 12
Freeland, WA 98249

Reference Number: **14-12064**
Project: **Bacteria**

System Name: **BEVERLY BEACH IMPROVEMENT CLUB**
System ID Number: **061475**
DOH Source Number: **00 - Distribution Sample (Bacteria)**
Sample Type: **D - Drinking Water**
Sample Purpose: **C - Compliance**
Sample Location: **X-3 Hose Bib**
County: **Island**
Sampled By: **Joe Waldrup**
Sampler Phone: **360-625-2457**

Repeat Sample Number:
Lab Number: **164-28599**
Field ID: **1**
Date Collected: **7/1/14 09:00**
Date Received: **7/1/14**
Date Analyzed: **7/02/14 11:42**
Report Date: **7/2/14**
Comment: **Cl2: 0.20**
Peer Review:

DOH#	PARAMETER	RESULT	Flag	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent		per 100mL	clc	SM9223 B	m_140701	
3	E. COLI	Absent		per 100mL		SM9223 B	m_140701	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: <http://www.skagitcounty.net/drinkingwater> or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:

If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.