



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club
PO BOX 12
Freeland, WA 98249

Reference Number: 15-16056
Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID Number: 061475
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: X - 2 Hose Bibb
County: Island
Sampled By: Joe Waldrup
Sampler Phone: 360-625-2457

Repeat Sample Number:
Lab Number: 164-35729
Field ID: 1
Date Collected: 8/4/15 09:15
Date Received: 8/4/15
Date Analyzed: 8/05/15 14:20
Report Date: 8/5/15
Comment: CI2: 0.40
Approved By: dml

Authorized by: 
Danielle Love
Chief Microbiologist

DOH#	PARAMETER	RESULT	UNITS	Analyst	METHOD	Batch	COMMENT
1	TOTAL COLIFORM	Satisfactory, Coliforms Absent	per 100mL	clc	SM9223 B	m_150804b	
3	E. COLI	Absent	per 100mL		SM9223 B	m_150804b	

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: [425-339-5250](http://www.snohomishcountywa.gov/health/ehp/dw/Programs/coliform.htm)
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.