



|                |                            |                          |                       |                             |
|----------------|----------------------------|--------------------------|-----------------------|-----------------------------|
| Burlington, WA | Corporate Laboratory (a)   | 1620 S Walnut St         | Burlington, WA 98233  | 800.755.9295 • 360.757.1400 |
| Bellingham, WA | Microbiology (b)           | 805 Orchard Dr Ste 4     | Bellingham, WA 98225  | 360.715.1212                |
| Portland, OR   | Microbiology/Chemistry (c) | 9150 SW Pioneer Ct Ste W | Wilsonville, OR 97070 | 503.682.7802                |
| Corvallis, OR  | Microbiology (d)           | 540 SW Third Street      | Corvallis, OR 97333   | 541.753.4946                |

## Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: Beverly Beach Improvement Club  
PO BOX 12  
Freeland, WA 98249

Reference Number: 16-02413  
Project: Bacteria

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
System ID Number: 061475  
DOH Source Number: 00 - Distribution Sample (Bacteria)  
Sample Type: D - Drinking Water  
Sample Purpose: C - Compliance  
Sample Location: X - 2 Hose Bib  
County: Island  
Sampled By: Joe Waldrup  
Sampler Phone: 360-625-2457

Repeat Sample Number:  
Lab Number: 164-05698  
Field ID: 1  
Date Collected: 2/2/16 09:00  
Date Received: 2/2/16  
Date Analyzed: 2/03/16 13:42  
Report Date: 2/4/16  
Comment: CI2: 0.36  
Approved By: dml

Authorized by: 

Danielle Love, MS  
Chief Microbiologist

| DOH# | PARAMETER      | RESULT                                | UNITS     | Analyst | METHOD   | Batch     | COMMENT |
|------|----------------|---------------------------------------|-----------|---------|----------|-----------|---------|
| 1    | TOTAL COLIFORM | <b>Satisfactory, Coliforms Absent</b> | per 100mL | clh     | SM9223 B | m_160202b |         |
| 3    | E. COLI        | <b>Absent</b>                         | per 100mL |         | SM9223 B | m_160202b |         |

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: [http://www.skagitcounty.net/drinkingwater\\_](http://www.skagitcounty.net/drinkingwater_) or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: [http://www.co.whatcom.wa.us/health/environmental/drinking\\_water/index.jsp](http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp)
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

**NOTES:**  
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.  
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.