



Burlington, WA	Corporate Laboratory (a)	1620 S Walnut St	Burlington, WA 98233	800.755.9295 • 360.757.1400
Bellingham, WA	Microbiology (b)	805 Orchard Dr Ste 4	Bellingham, WA 98225	360.715.1212
Portland, OR	Microbiology/Chemistry (c)	9150 SW Pioneer Ct Ste W	Wilsonville, OR 97070	503.682.7802
Corvallis, OR	Microbiology (d)	540 SW Third Street	Corvallis, OR 97333	541.753.4946

INORGANIC COMPOUNDS (IOC) REPORT

Client Name: **Beverly Beach Improvement Club**
PO BOX 12
Freeland, WA 98249

Reference Number: **17-09268**
 Project: **Asbestos**

System Name: **BEVERLY BEACH IMPROVEMENT CLUB**
 System ID Number: **061475**
 DOH Source Number: **02**
 Multiple Sources:
 Sample Type: **B - Before treatment**
 Sample Purpose: **C - Compliance**
 Sample Location: **Well Head**
 County: **Island**

Sample Number:
 Lab Number: **186-21910**
 Collect Date: **4/25/17 08:00**
 Date Received: **4/25/17**
 Report Date: **5/17/17**
 Sampled By: **Joe Waldrup**
 Sampler Phone: **360-929-2358**
 Approved by: **fm**
 Authorized by:


 Lawrence J Henderson, PhD
 Director of Laboratories, Vice President

DOH#	ANALYTES	RESULTS	UNITS	SRL	Trigger	MCL	Analyst	METHOD	Lab	Analyzed	COMMENT
0	ASBESTOS	ND	MFL>10um	0.098			be	100.2		05/16/17	Analyzed by EMSL

NOTES:

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).
 MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.
 Trigger Level: DOH Drinking Water Response level. Systems with compounds detected in excess of this level are required to take additional samples. Contact your regional DOH office.
 ND (Not Detected): indicates that the parameter was not detected above the Specified Reporting Limit (SRL).

If you have any questions concerning this report contact Lawrence J Henderson, PhD, Director of Laboratories, Vice President, at the toll-free phone number above.