



| | | | | |
|----------------|----------------------------|--------------------------|-----------------------|-----------------------------|
| Burlington, WA | Corporate Laboratory (a) | 1620 S Walnut St | Burlington, WA 98233 | 800.755.9295 • 360.757.1400 |
| Bellingham, WA | Microbiology (b) | 805 Orchard Dr Ste 4 | Bellingham, WA 98225 | 360.715.1212 |
| Portland, OR | Microbiology/Chemistry (c) | 9150 SW Pioneer Ct Ste W | Wilsonville, OR 97070 | 503.682.7802 |
| Corvallis, OR | Microbiology (d) | 540 SW Third Street | Corvallis, OR 97333 | 541.753.4946 |




Washington State Department of Health WATER BACTERIOLOGICAL ANALYSIS

Client Name: WWSVC - Beverly Beach Improvement Club
14263 Calhoun Road
Mount Vernon, WA 98273

Reference Number: 18-07330
Project: Beverly Beach Improvement Club

System Name: BEVERLY BEACH IMPROVEMENT CLUB
System ID Number: 061475
DOH Source Number: 00 - Distribution Sample (Bacteria)
Sample Type: D - Drinking Water
Sample Purpose: C - Compliance
Sample Location: 4010 Alder
County: Island
Sampled By: Larry H
Sampler Phone:

Repeat Sample Number:
Lab Number: 164-15247
Field ID: 1040171471
Date Collected: 3/5/18 08:55
Date Received: 3/5/18
Date Set: 3/5/18 17:35
Date Analyzed: 3/6/18 12:18
Report Date: 3/6/18
Comment: Cl2: 0.02
Approved By: ckk,jfh

Authorized by: 
Ceann K Knox
Lab Manager, Bellingham

| DOH# | PARAMETER | RESULT | Qualifier | UNITS | Analyst | METHOD | Batch | COMMENT |
|------|----------------|---------------------------------------|-----------|-----------|---------|----------|-----------|---------|
| 1 | TOTAL COLIFORM | Satisfactory, Coliforms Absent | | per 100mL | jma | SM9223 B | m_180305b | |
| 3 | E. COLI | Absent | | per 100mL | | SM9223 B | m_180305b | |

If the sample is unsatisfactory you can get information at the following health department websites or phone numbers:

- Island Co: <http://www.islandcounty.net/health/Envh/DrinkingWater/index.htm>
- San Juan Co: <http://www.sanjuanco.com/health/ehswater.aspx>
- Skagit Co: http://www.skagitcounty.net/drinkingwater_ or 360-336-9380
- Snohomish Co: 425-339-5250
- Whatcom Co: http://www.co.whatcom.wa.us/health/environmental/drinking_water/index.jsp
- WSDOH: <http://www.doh.wa.gov/ehp/dw/Programs/coliform.htm>

NOTES:
If the result is Unsatisfactory a repeat sample is required for Public Water Systems. Private individuals should investigate the cause of the unsatisfactory result and resample.
If E. Coli or Fecal Coliform are present in sample do not drink the water until it is properly treated.
*If data qualifiers are present, see accompanying Qualifier Definition report.