



Burlington WA  
Corporate Office


Bellingham WA  
Microbiology

Portland OR  
Microbiology/Chemistry

1620 S Walnut St - 98233  
800.755.9295 • 360.757.1400

805 Orchard Dr Ste 4 - 98225  
360.671.0688

9150 SW Pioneer Ct Ste W- 97070  
503.682.7802



## INORGANIC COMPOUNDS (IOC) REPORT FOR LEAD & COPPER

Client Name: Beverly Beach Improvement Club  
PO BOX 12  
Freeland, WA 98249

Reference Number: 11-14422

Project: Lead & Copper

System Name: BEVERLY BEACH IMPROVEMENT CLUB  
System ID Number: 06147  
DOH Source Number: 93

Analyst: mvp  
Date Received: 9/12/2011  
Report Date: 9/22/2011

Multiple Sources:  
Sample Type: A  
Sample Purpose: C  
County: Island

Approved By:

DOH#	23 (Copper)	9 (Lead)
SRL	0.02 mg/L	0.002 mg/L
AL	1.3 mg/L	0.015 mg/L

Lab Number	Date Collected	Site / Location	Copper mg/L	Lead mg/L	METHOD
046-31809	9/8/11	4278 Maple Ave Freeland 98249	0.018	ND	200.8
046-31810	9/8/11	4084 Alder Avenue	0.038	0.006	200.8
046-31811	9/8/11	4062 Beach Dr, Freeland, WA. 98249	0.050	ND	200.8
046-31812	9/8/11	1868 Foliage St., Freeland, WA. 98249	0.058	0.001	200.8
046-31813	9/8/11	4195 Bass Wood Rd. Kitchen Sink	0.017	ND	200.8

**NOTES:**

SRL (State Reporting Level): indicates the minimum reporting level required by the Washington Department of Health (DOH).

MCL (Maximum Contaminant Level) maximum permissible level of a contaminant in water established by EPA; Federal Action Levels are 0.015 mg/L for Lead and 1.3 mg/L for Copper. Sodium has a recommended limit of 20 mg/L. A blank MCL value indicates a level is not currently established.

ND (Not Detected): indicates that the compound was not detected above the Specified Reporting Limit (SRL).

These test results meet all the requirements of NELAC, unless otherwise stated in writing, and relate only to these samples. If you have any questions concerning this report contact Lawrence Henderson at the above phone number.