

Beverly Beach Improvement Club  
P.O. Box 12  
Freeland WA. 98249

March 21<sup>st</sup> 2012

Manganese & Iron Test

Manganese after treatment 0.015 MG/L (MCL 0.05 MG/L)

Iron after treatment 0.0037 MG/L (MCL 0.03 MG/L)

These tests were done with our 870 DPD Tester.

Joe Waldrup  
Water/Manager