



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: November 2017

For the month of November the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 11/01/17 to 11/29/17</i>	Current Month 29 Days	Last Month -- Days	Difference	Last Year -- Days	Difference
Total Production	186,630	N/A		N/A	
Daily Avg.	6,436	N/A	N/A	N/A	N/A
GPD/Home - 53	121	N/A	N/A	N/A	N/A

Miscellaneous

- 11/15- Collected compliance bacteria sample at 1842 Foliage Street.
- 11/22- Flushed Alder/Beach Drive; 6,000 gallons of water to waste.
- 11/27- Took well depth with sounder, well measured 233.91' pumping.