



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: April 2018

For the month of April the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 3/30/18 to 4/30/18</i>	Current Month 31 Days	Last Month 32 Days	Difference	Last Year -- Days	Difference
Total Production	216,500	213,600		N/A	
Daily Avg.	6,984	6,675	+4%	N/A	N/A
GPD/Home - 53	132	126	+5%	N/A	N/A

Miscellaneous

- 4/02 – Flushed north end of system for 30 minutes; flushed 9,000 gallons of water to waste
- 4/02 – Repaired pre-filter chlorine injection line.
- 4/06 – Added 5 gallons of chlorine to pre-filter tank.
- 4/09 – Collected monthly routine compliance bacteria sample at 1868 Foliage
- 4/16 – Attended meeting with contractors to discuss Spruce Street mainline extension.
- 4/18 – Permanganate injection fault; primed injection pump to resolve issue.
- 4/18 – Flushed system; flushed 6,000 gallons of water to waste
- 4/03 – Performed chloride/conductivity test.
- 4/25 – Onsite with contractor for Spruce Street mainline extension. Pressurized and tested new construction – PASSED.