



Board of Directors  
**Beverly Beach Improvement Club**  
 Monthly Report of System Operation  
**Month:** August 2018

For the month of August the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

**Production**

<i>Based on Daily Log Sheets from 7/30/18 to 8/31/18</i>	<b>Current Month 32 Days</b>	<b>Last Month 31 Days</b>	<b>Difference</b>	<b>Last Year -- Days</b>	<b>Difference</b>
<b>Total Production</b>	411,400	514,800		N/A	
<b>Daily Avg.</b>	12,856	16,606	-23%	N/A	N/A
<b>GPD/Home - 108</b>	119	154	-23%	N/A	N/A

**Miscellaneous**

- 8/01- Met with AquaTech and Robin for well pump inspection.
- 8/01- Replaced pre-filter chlorine injection point. Faulty check valve/plugged injector.
- 8/06- Cleaned and refilled post filter chlorine tank, primed pump.
- 8/10- Took monthly well depth with well depth sounder, well measured 229.15' static.
- 8/13- Collected monthly compliance bacteria sample at 4170 Beach Drive.
- 8/13- Collected compliance Chloride & Conductivity sample.
- 8/13- Pre-filter chlorine injection line clogged with debris. Flushed line, flow increased.
- 8/17- Well drawdown test; 224.5' static and 228.8' pumping.
- 8/20- Collected annual compliance nitrate sample at S02 post reservoir tap.
- 8/24- Replaced chlorine pump injection tubing and O-rings.
- 8/31- 9,600 gallons of water was backwashed in August.