



Board of Directors  
**Beverly Beach Improvement Club**  
 Monthly Report of System Operation  
**Month:** February 2018

For the month of February the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

**Production**

<i>Based on Daily Log Sheets from 1/31/18 to 2/26/18</i>	<b>Current Month 26 Days</b>	<b>Last Month 33 Days</b>	<b>Difference</b>	<b>Last Year -- Days</b>	<b>Difference</b>
<b>Total Production</b>	115,500	185,840		136,420	
<b>Daily Avg.</b>	4,442	5,632	-21%	N/A	N/A
<b>GPD/Home - 53</b>	84	106	-21%	N/A	N/A

**Miscellaneous**

2/05- Collected compliance bacteria sample at 4170 Beach Drive.  
 2/12- Breaker for lights and air conditioner was tripped, reset.  
 2/23- Turned well pump from auto to off to run down tank, will test running in larger batches to reach efficiency of filtration system.