



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: July 2018

For the month of July the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 6/29/18 to 7/30/18/18</i>	Current Month 31 Days	Last Month 30 Days	Difference	Last Year -- Days	Difference
Total Production	514,800	345,200		N/A	
Daily Avg.	16,606	11,507	+31%	N/A	N/A
GPD/Home - 53	313	217	+31%	N/A	N/A

Miscellaneous

- 7/06- Took monthly well depth with well depth sounder, well measured 229.78' static.
- 7/09- Collected monthly compliance bacteria sample at 1868 Foliage.
- 7/20- Air compressor breaker tripped, reset.
- 7/23- 4298 Basswood Cross Connection evaluation (well)/water system connection approval evaluation.
- 7/25- Transferred post filter chlorine to pre-filter chlorine tank.