



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: June 2018

For the month of June the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 5/30/18 to 6/29/18</i>	Current Month 30 Days	Last Month 30 Days	Difference	Last Year -- Days	Difference
Total Production	345,200	283,700		N/A	
Daily Avg.	11,507	9,457	+18%	N/A	N/A
GPD/Home - 53	217	178	+18%	N/A	N/A

Miscellaneous

6/04- Collected monthly compliance bacteria sample at 4010 Alder.
 6/08- Bi-weekly system flush; a total of 6,000 gallon of water flushed to waste.
 6/08- Beach/Spruce hydrant valve may be detached from stem. Opens, but does not closed. Closed foot valve and bagged hydrant.
 6/11- Took monthly well depth with well depth sounder, well measured 229.39' static.
 6/20- Hydrant Inspections. #4: 5 ¼" cap stuck. #10: Hydrant left full open. Closed, freed caps.
 #9: All caps stuck. Freed all. #6: Lower valve stem break under breakaway coupling. Closed at road valve. All other hydrants operate and drain normally.