



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: March 2018

For the month of March the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 2/26/18 to 3/30/18</i>	Current Month 32 Days	Last Month 26 Days	Difference	Last Year -- Days	Difference
Total Production	213,600	115,500		143,650	
Daily Avg.	6,675	4,442	+33%	N/A	N/A
GPD/Home - 53	126	84	+33%	N/A	N/A

Miscellaneous

- 3/01- Read system meters.
- 3/01- Took well depth with sounder, well #1 measured 229.25' static.
- 3/05- Ran plant in auto.
- 3/05- Collected monthly routine compliance bacteria sample at 4010 Alder.
- 3/07- Flushed.
- 3/09- Post filter chlorine pump online. Adjusted tank level controls, lowered "ON" setpoint, new ON/OFF
- 3/16- Reservoir hatch seal gaskets "ok", hatch corners are corroded, no evidence of contaminant entry.
- 3/19- Flushed north end of system; flushed 12,000 gallons of water to waste.