



Board of Directors
Beverly Beach Improvement Club
 Monthly Report of System Operation
Month: May 2018

For the month of May the Beverly Beach Improvement Club water system ran well. Monthly bacterial results met state DOH requirements.

Production

<i>Based on Daily Log Sheets from 4/30/18 to 5/30/18</i>	Current Month 30 Days	Last Month 31 Days	Difference	Last Year -- Days	Difference
Total Production	283,700	216,500		N/A	
Daily Avg.	9,457	6,984	+26%	N/A	N/A
GPD/Home - 53	178	132	+26%	N/A	N/A

Miscellaneous

- 5/02- Flushed North end of system; a total of 6,000 gallons of water flushed to waste.
- 5/02- Collected monthly routine compliance bacteria sample at 4170 Beach Drive.
- 5/14- Repaired leak on chlorine injection line.
- 5/18- Installed meter at Lot 137.
- 5/18- Flushed North end of system; a total of 6,000 gallons of water flushed to waste.
- 5/28- Yard Maintenance; mowed around all hydrants and valves in system.
- 5/30- Checked service leak at 4294 Maple, excavated and found old gate valve leaking.
- 5/30- Trico Spruce Street Project; cut out Beach Drive tap and installed tee and 2" gate valve, extended poly line and installed blow-off and four (4) services. Backfilled.
- 5/30- Took monthly well depth with well depth probe, well measured 230.5' static.